

BAKER ROAD MUNICIPAL UTILITY DISTRICT

2025 Drinking Water Quality Report

We are pleased to present you the Annual Water Quality Report (Consumer Confidence Report) for the year 2025, for the period of January 1 to December 31, 2025. This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

(Este informe contiene informacion muy importante sobre su agua potable. Traduzcalo o hable con alguien que lo entienda bien. Para mas informacion favor de llamar al telefono: (281) 353-9809.)

Sources of Drinking Water

Our water source(s) and source assessment information are listed below:

BAKER ROAD MUD purchases groundwater. It comes from the Gulf Coast Aquifers located in Harris County, some 500 to 2,000 feet below ground surface. We purchase this water from Green Trails Municipal Utility District on a year-round basis as a permanent water supply source. The TCEQ has completed a Source Water Susceptibility Assessment for all drinking water systems that own their sources.

The report describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The system from which we purchase our water received the assessment report. For more information regarding this report, on source water assessments and protection efforts at our system, please contact: Natalia Espitia at (281) 353-9809.

Source Name		Type of Water	Report Status	Location
GW FROM GREEN TRAILS MUD	CC FROM TX1011839 GREEN TRAILS MUD	Ground Water	Yes	https://gisweb.tceq.texas.gov/swat/print/1012962

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animal or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791) or USEPA website: www.epa.gov/safewater.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic system, agricultural livestock operations, and wildlife;
- **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban stormwater, runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming;
- **Pesticides and Herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;
- **Organic Chemical Contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and
- **Radioactive Contaminants**, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA prescribes regulations that limits the amount of certain contaminants in water provided by public water systems. Federal Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

Special Notice for the ELDERLY, INFANTS, CANCER PATIENTS, people with HIV/AIDS or other immune problems:

Some people may be more vulnerable to contaminants in drinking water than the general population. Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the District's operator, H₂O Innovation (281) 353-9809

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care provider. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Our drinking water is delivered by wells from underground aquifers that are protected from many of the sources of contamination described.

Public Participation Opportunities:

The Baker Road M.U.D Board of Directors meet on the fourth Monday of every month at 12:00 p.m. at 1300 Post Oak Blvd, Suite 2500, Houston, Texas. You may contact Natalia Espitia or Brenda Landin, with H₂O Innovation at 281-353-9809 with any concerns or questions.



About the Following Tables

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definition:

DEFINITIONS:

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Treatment Technique or TT: A required process intended to reduce the level of a contaminant in drinking water.

Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Avg; Average - Regulatory compliance with some MCLs are based on running annual average of monthly samples.

RAA: Running Annual Average.

LRAA: Locational Running Annual Average.

mrem: millirems per year (a measure of radiation absorbed by the body).

ppb: micrograms per liter (ug/L) or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter (mg/L) or parts per million - or one ounce in 7,350 gallons of water.

picocuries per liter (pCi/L): picocuries per liter is a measure of the radioactivity in water.

na: not applicable.

Baker Road M.U.D. Public Water System ID: TX1012962 2025 Drinking Water Quality Report:

Disinfectant Residual

All public water systems in Texas are required to disinfect drinking water to ensure control of microbial contaminants. Disinfectants are water additives used to control microbes.

Disinfectant Residual								
Year	Constituent	Highest Average	Range of Detected Levels	MRDL	MRDLG	Units of Measure	Violation	Source of Constituent
2025	Chlorine Disinfectant	1.58	1.22 - 1.97	4	4	ppm	N	Water additive used to control microbes.

Regulated Contaminants

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Lead and Copper	Period	90TH Percentile: 90% of your water utility level were less than	Range of Sampled Results (low - high)	Unit	Action Level (AL)	Sites Over AL	Typical Source
Copper, Free	2022 - 2024	0.135	0.0224 - 0.246	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead	2022 - 2024	0.844	0 - 1.03	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. **BAKER ROAD MUD** is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact **BAKER ROAD MUD** at 713-623-4531. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

Lead Service Line Inventory Statement

A service line inventory has been prepared and can be accessed at: [Baker Road Municipal Utility District Information & Reports - Customer Portal - H2O](#)
As part of the U.S. Environmental Protection Agency's (EPA) revised Lead and Copper Rule, **Baker Road M.U.D.** has completed a full inventory of service lines within our water distribution system, including both the public (utility-owned) and private (customer-owned) portions of each service connection.

Based on a thorough review of historical records, customer outreach, and material verification, no lead or galvanized service lines requiring replacement were identified on either the public or private side of our system. All service lines are confirmed to be made of non-lead materials such as copper, plastic, or other EPA-approved materials.

Although no lead service lines were found, we remain proactive in maintaining accurate records and ensuring ongoing compliance with all regulatory requirements. If you have questions about your service line material, would like to view our inventory, or are interested in voluntary water testing, please contact us at cs.compliance@h2oinnovation.com or by phone at 281-353-9809.

Organic Contaminants								
Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	19039 WINDSOR PALMS, HOUSTON	2025	0	0	ppb	60	0	By-product of drinking water disinfection
TTHM	19039 WINDSOR PALMS, HOUSTON	2025	2	2.2	ppb	80	0	By-product of drinking water chlorination.

*The value in the Highest Level or Average Detected column is the highest average of all TTHM / HAA5 sample results collected at a location over a year

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
DIBROMOCHLOROMETHANE	08/20/2025	1.1	1.1	UG/L	60	0	By-product of drinking water disinfection

Additional Required Health Effects Language:

There are no additional required health effects notices or violations.

During 2025, Baker Road M.U.D. TX 1012962 received all of its water from a well operated by Green Trails M.U.D. TX1011839 Green Trails M.U.D. provided the following water quality information:

For additional information relating to Green Trails source water please contact Municipal Operations & Consulting Attn: Koby K. Boman (281) 367-5511.

Inorganic Contaminants							
Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
ARSENIC	02/06/2024	7	7.00 - 7.00	ppb	10	0	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
BARIUM	02/06/2024	0.17	0.17 - 0.17	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
DIBROMOCHLORO-METHANE	09/04/2025	2	0 - 2	UG/L	60	0.	By-product of drinking water chlorination
FLUORIDE	02/06/2024	0.48	0.48 - 0.48	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories

*While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Radioactive Contaminants							
Radiological Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
COMBINED RADIUM (-226 & -228)	06/09/2021	1.50	1.50 - 1.50	pCi/L	5	0	Erosion of natural deposits.

*Unregulated Contaminants					
Year	Constituent	Average of All Sampling Points	Range of Detected Levels	Violation	Units of Measure
2024	CHLOROFORM	40.30	40.30 - 40.30	N	ppb
2025	BROMODICHLOROMETHANE	11.00	11.00 - 11.00	N	ppb
2025	BROMOFORM	1.60	1.60 - 1.60	N	ppb
2024	DICHLOROACETIC ACID	4.40	4.40 - 4.40	N	ppb
2024	BROMOCHLOROACETIC ACID	1.10	1.10 - 1.10	N	ppb

*Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

Synthetic Organic Contaminants								
Year	Constituent	Highest Detected Level at Any Sampling Point	Range of Detected Levels	MCL	MCLG	Units of Measure	Violation	Source of Constituent
2024	Di (2-ethylhexyl) phthalate	1.9	1.9 - 1.9	6	0	ppb	N	Discharge from rubber and chemical factories.

Volatile Organic Contaminants								
Year	Constituent	Highest Detected Level at Any Sampling Point	Range of Detected Levels	MCL	MCLG	Units of Measure	Violation	Source of Constituent
2023	Xylenes	0.0005	0.0005 - 0.0005	10	10	ppm	N	Discharge from petroleum factories.

Organic Contaminants									
Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source	
TOTAL HALOACETIC ACIDS (HAA5)	1222 EMERALD GREEN LN, HOUSTON, TX	2025	0	0	ppb	60	0	By-product of drinking water disinfection	
TTHM	1222 EMERALD GREEN LN, HOUSTON, TX	2025	5	4.6	ppb	80	0	By-product of drinking water chlorination	

**The value in the Highest Level or Average Detected column is the highest average of all TTHM/HAA5 sample results collected at a location over a year